

Wiikwemkoong Unceded Territory

19 A Complex Drive, P.O. Box 112
Wikwemikong, Ontario P0P 2J0

October 30, 2026

KWIINWIN KENDI-MOOKIIWIN **Precautionary Boil Water Advisory - Upper Pressure Zone**

Please be advised that the Public Works Department will be issuing a Precautionary Boil Water Advisory for residents and facilities located within the Upper Pressure Zone.

This area includes:

- Henry Street (including the High School)
- Genevieve Street
- Christine Avenue
- Andrew Crescent
- Tower Street

The advisory is being issued after the elevated water storage tower was depleted overnight. It was determined that water levels in the in-ground reservoir became too low, which prevented the pumps from supplying water to the elevated storage tower. The tower is currently being refilled; however, it will take some time before normal operating levels are restored.

As a precautionary measure, water quality sampling will be conducted. The advisory will remain in effect until the required testing has been completed and satisfactory results have been received.

Please note that this situation only affects the Upper Pressure Zone. Residents and facilities within the Lower Pressure Zone, which encompasses the remainder of the Village, are not affected by this advisory at this time.

In addition, rural water delivery services have been suspended until Sunday to allow sufficient time for the reservoirs and storage systems to recover. Residents who were expecting water deliveries today will not receive service until Sunday and are asked to conserve water until deliveries resume.

Public Works staff are actively monitoring the system and will provide updates as additional information becomes available.

Miigwech,
Norman Assiniwe
Public Works Manager

www.wiikwemkoong.ca
Telephone: (705) 859-3122
Fax: (705) 859-3851